

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Miscellaneous Fittings for Pressurised Equipment

with type designation(s)
SprayStop Standard, SprayStop 50 Plus (one layer)

Issued to
T-ISS B.V.
Dinxperlo Gelderland, Netherlands

is found to comply with
DNV GL rules for classification – Ships

Application :

Screening of pipe joints and fittings in accordance with SOLAS Chapter II-2, Regulation 4, item 2.2.5.3

Type:	Temperature range:	Design pressure:	Operating media:
SprayStop Standard	150 degrees Celsius	15 barg internal pressure	Fuel oil, lube oil and other flammable oils
SprayStop 50 Plus (one layer)	150 degrees Celsius	37 barg internal pressure	Fuel oil, lube oil and other flammable oils

Issued at **Høvik** on **2017-08-31**

This Certificate is valid until **2022-08-30**.
DNV GL local station: **Rotterdam, Offshore & Newbuilding**

Approval Engineer: **Ole Henrik Kverndal Pedersen**



for **DNV GL**

Digitally Signed By: **Torill Grimstad Osberg**
DNV GL Høvik, Norway

Torill Grimstad Osberg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

